

September Board Report

Happenings:

- Completed the HS commons HVAC project everything is up and operational
- Completed with the K6 controls outside of a couple punchlist items
- Had water main at K6 break right before school started it was repaired shortly after discovering it
- We have been working through issues with debris in our HVAC loop at the K6 cleaning screens, flushing units, flushing air separators, ect. We believe we are on the back side of most of this issue. We may possibly need to have the heat exchanger cleaned and flushed at the beginning of this coming summer.
- We have been very busy setting up for events making the big push to have the entrance ready and parking changes in order for the first football game as well as setting up for the home cross country meet
- Spread gravel for all of the drives south of the high school
- Installation completed for railing in front of high school
- Replaced north gym doors at HS that were very weak and leaky